

DAILY POOL CHEMICAL LOG

Pool _____

Date _____

Item	1 st	2 nd	3 rd	4 th	Standard		
					(min	ideal	max)
Time	_____	_____	_____	_____			
FAC / BR	_____	_____	_____	_____	1	2-4	5 ppm
CAC	_____	_____	_____	_____	0	0	0.2 pool (0.5 spas)
pH	_____	_____	_____	_____	7.2	7.4-7.6	7.8
ORP	_____	_____	_____	_____	650 or code compliance		
Total Alkalinity	_____	_____	_____	_____	60	80-120	180 ppm
Cyanuric Acid	_____	_____	_____	_____	30-50	150 ppm	
Calcium Hardness	_____	_____	_____	_____	150	200-400	1000 ppm
Water Temperature	_____	_____	_____	_____	NA	78-82°F	104°F
Air Temperature	_____	_____	_____	_____			
TDS	_____	_____	_____	_____			
Saturation Index	_____	_____	_____	_____	-0.3 to +0.3		
Water Clarity	_____	_____	_____	_____	main drain clearly visible		
Water Level	_____	_____	_____	_____	1/8 – 1/4 inch above gutter		
Bather load	_____	_____	_____	_____			
Flowrate	_____	_____	_____	_____			
Turnover	_____	_____	_____	_____			
Influent Pressure	_____	_____	_____	_____			
Effluent Pressure	_____	_____	_____	_____			
Pressure Differential	_____	_____	_____	_____			
Initialed by:	_____	_____	_____	_____			
Time Test Taken:	_____	_____	_____	_____			

Optional test: nitrates (ideal-none, max 10 ppm), phosphates (ideal-none, max 2.0 ppm), iron (ideal-none), copper (ideal-none)

NOTES: _____

CHEMICALS ADDED:
Opening: _____

Closing: _____
